

Certificate of Constancy of Performance



Certificate n° 0757-CPR-277-8017423-3-2

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Windows with fire resistance and smoke control characteristics

**Schüco AWS 60 FR 30 / AWS 60.HI FR 30 /
AWS 70 FR 30 / AWS 70.HI FR 30 /
AWS 75 FR 30 / AWS 90 FR 30**

Trade name

Product description/
specification

Windows according to EN 14351-1:2006+A2:2016
with fire resistance and smoke control characteristics
according to EN 16034:2014

Construction and classification: see EXAP report n°
18-002404-PR03 and classification report n° 18-0024 04-PR04

Levels and classes of
performance

According to configuration in **annex 1**

Intended use(s)

- Installation in residential and non-residential construction
- In the case of room partitioning into fire and/or smoke protection sections and/or escape routes

placed on the market
under the name or trade
mark of

PICHLER Projects GmbH

Edisonstr. 15, IT-39100 Bozen

and produced in the
manufacturing plant(s)

PICHLER Projects GmbH

Edisonstr. 15, IT-39100 Bozen

Notified body No.
EC-Reference-No.

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)


EN 14351-1:2006+A2:2016 and EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 13.10.2020 and will remain valid until 12.10.2026, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.


The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 277 8017423.

Christian Kehrer
Head of notified product certification body
ift Rosenheim
13.10.2023



Basis:

EN 16034
EN 14351-1



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/
ift-zertifiziert
ID: 6DE-6E206

Certificate of constancy of performance

Annex 1
Certificate holder: PICHLER Projects GmbH
Date of issue: 13.10.2023



Certificate n°: 0757-CPR-277-8017423-3-2

Product description:

Essential characteristics according to EN 16034	Performance
Fire resistance (in the case of room partitioning into fire and/or smoke protection sections)	NPD / E 15 / E 20 / E 30 NPD / EW 15 / EW 20 / EW 30 NPD / EI ₂ 15 / EI ₂ 20 / EI ₂ 30 NPD / EI ₁ 15 / EI ₁ 20 / EI ₁ 30
Smoke control (only for applications where smoke spread limitation is required)	NPD / S _a / S ₂₀₀
Ability to release	NPD
Self-closing action (only for self-closing fire and/or smoke protection doors and/or windows)	NPD / C
Durability of ability to release	NPD
Durability of self-closing (only for self-closing fire and/or smoke protection doors and/or windows) – Compared with loss of quality (resistance to repeated opening and closing) – Compared with ageing (corrosion)	NPD / 0 / 1 / 2 NPD / Achieved