Certificate of Constancy of Performance

Certificate No.: 0757-CPR-231-8017669-3-1

Basis:

EN 1154

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Controlled door closing devices

Product description/ specification	**TS77 C** According to configuration in **annex 1**
Levels and classes of performance	According to configuration in **annex 1**
Intended use(s)	Intended for use on hinged doors with requirements for fire resistance and smoke control
placed on the market under the name or trade mark of	**dormakaba Deutschland GmbH** DORMA Platz 1, DE-58256 Ennepetal
and produced in the manufacturing plant(s)	**9007068**
Notified body No.	**0757**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 1154 : 1996-11+A1:2002-12+AC:2006-06

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 12.10.2026 and will remain valid until 11.10.2029, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 231 8017669.

ift Rosenheim GmbH Theodor-Gietl-Str. 7-9 83026 Rosenheim Germany Notified Body 0757

Dr. Gerhard Wackerbauer
Deputy head of the notified product certification body
Certification & Surveillance Body
ift Rosenheim
12.10.2026

www.ec.europa.eu

Identity check

www.ift-rosenheim.de/ift-zertifiziert
ID: 36A-8E8FA

Ve-Zer-5113-en / 2025-02

Certificate of constancy of performance

Certificate holder: **dormakaba Deutschland GmbH**
Date of issue: **12.10.2026**

Certificate No.: 0757-CPR-231-8017669-3-1

Compilation of door closing devices:

Classification key

1	2	3	4	5	6
Category of use	Mechanical durability	Closing device size	Suitability for use one fire / smoke doors	Safety	Corrosion resistance

no.	product	Reference-test report	Item	1	2	3	4	5	6
1	TS77 C	12-001020-PR05 27.06.2013, 13-003990-PR03 11.02.2015	upper door closer with stay arm	4	8	3	1	1	3