

Certificate of Constancy of Performance



Certificate No.: 0757-CPR-288-9028184-1-1

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Basis:

EN 12101-2:2003-06

Smoke and heat control system (NSHEV)

AUMÜLLER ferralux® NRWG 100 ALIPLAST

Product description/
specification

Profile system: ALIPLAST
see ift Product Passport no. 16-004337-PR12

Levels and classes of
performance

Requirements fulfilled

Intended use(s)

This NSHEV was tested without side wind influence. Therefore, use of this NSHEV is allowed only in mounting positions without risk caused by exposure to side wind flow i.e. use in side walls. For notes on use refer to product passport no. 16-004337-PR12. Design and dimensions of the NSHEV are subject to the relevant national rules and regulations concerning use and application.

placed on the market
under the name or trade
mark of

F.H.U.P. Krystyna Rupar

Bialobrzegi 3i, PL-37-114 Bialobrzegi

and produced in the
manufacturing plant(s)

F.H.U.P. Krystyna Rupar

Bialobrzegi 3i, PL-37-114 Bialobrzegi

Notified body No.
EC-Reference-No.

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12101-2 : 2003

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 06.02.2020 and will remain valid until 05.02.2023, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.


The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 288 9028184.

Prof. Jörn P. Lass
Director

ift Rosenheim
06.02.2020



Christian Kehrer
Head of notified product certification body



www.ec.europa.eu



www.ift-rosenheim.de