

Certificate of Constancy of Performance



Certificate No.: 0757-CPR-229EG-7051574-13-7

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Door hinges

Product description/
specification

Dynamic 2D

(D2D, D2DF, D2DA, D2DCXX, D2DTA)

According to configuration in **annex 1**

Levels and classes of
performance

According to configuration in **annex 1**

Intended use(s)

Intended for use on doors in escape routes without requirements for fire resistance and smoke control

placed on the market
under the name or trade
mark of

SFS Group Italy S.r.l. unipersonale

Via Castelfranco Veneto, 71, IT-33170 Pordenone

and produced in the
manufacturing plant(s)

SFS Group Italy S.r.l. unipersonale

Via Castelfranco Veneto, 71, IT-33170 Pordenone

Notified body No.
EC-Reference-No.

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 1935 : 2002

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 22.01.2014 and will remain valid until 20.04.2026, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.


The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 229EG 7051574.

Christian Kehr
Head of notified product certification body
ift Rosenheim
21.04.2023



Basis:

EN 1935-2002-02/AC:2003-12



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/
ift-zertifiziert
ID: 36C-A7134

Certificate of constancy of performance

Annex 1 Page 1 of 5
Certificate holder: SFS Group Italy S.r.l. unipersonale
Date of issue: 21.04.2023



Certificate No.: 0757-CPR-229EG-7051574-13-7

Compilation of hinges

No. 1:

Product designation: **D2D 160007**
Hinge type: two-parts door hinge Material number: 1287815
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for
fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

No. 2:

Product designation: **D2D 16F008**
Hinge type: two-parts door hinge Material number: 1292901
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for
fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

Certificate of constancy of performance

Annex 1 Page 2 of 5
Certificate holder: SFS Group Italy S.r.l. unipersonale
Date of issue: 21.04.2023



Certificate No.: 0757-CPR-229EG-7051574-13-7

No. 3:

Product designation: **D2D 16F009**
Hinge type: two-parts door hinge Material number: 1292877
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

No. 4:

Product designation: **D2D 16F010**
Hinge type: two-parts door hinge Material number: 1316375
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

No. 5:

Product designation: **D2D 16F011**
Hinge type: two-parts door hinge Material number: 1317468
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

Certificate of constancy of performance

Annex 1 Page 3 of 5
Certificate holder: SFS Group Italy S.r.l. unipersonale
Date of issue: 21.04.2023



Certificate No.: 0757-CPR-229EG-7051574-13-7

No. 6:

Product designation: **D2D 16MD0008**
Hinge type: two-parts door hinge Material number: 1309013
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for
fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

No. 7:

Product designation: **D2DF 16F002**
Hinge type: two-parts door hinge Material number: 1309015
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for
fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

No. 8:

Product designation: **D2DA 160000**
Hinge type: two-parts door hinge Material number: 1286558
Material: Steel
Fastening: screw-fitted into aluminium receptacles with 3 screws
M5 x 20mm on the frame and 4 hinge accessories screws on the sash for
fixing the hinge
Test report: 12-002890-PR02 of 29.05.2013

Classification:	3	7	4	0	1	4	0	11
-----------------	---	---	---	---	---	---	---	----

Intended use: Intended for use on doors in escape routes

Certificate of constancy of performance

Annex 1 Page 4 of 5
Certificate holder: SFS Group Italy S.r.l. unipersonale
Date of issue: 21.04.2023



Certificate No.: 0757-CPR-229EG-7051574-13-7

No. 9:

Product designation: **D2DC03**
Hinge type: single-axis two-part door hinge
Material: Steel
Fastening: screw-fitted with 4 screws in frame element
M4 x 15 mm (strength class 10.9);
screw-fitted with 4 screws in leaf element
M5 x 25 mm (strength class 10.9)
Test report: 18-004024-PR01 of 26.03.2019

Classification:	3	7	4	0	1	4*	0	11
-----------------	---	---	---	---	---	----	---	----

*tested and passed up to corrosion class 5

Intended use: Intended for use on doors in escape routes

No. 10:

Product designation: **D2DTA 0000**
Hinge type: single-axis three-part door hinge
Material: steel and zamak
Fastening: screw-fitted with 3 screws in frame element
screw-fitted with 4 screws in leaf element
Test report: 20-004336-PR04 of 21.02.2022

Classification:	2	7	3	0	1	4*	0	10
-----------------	---	---	---	---	---	----	---	----

*Corrosion resistance Class 5 positive, according to EN 1670:2007

Intended use: Intended for use on doors in escape routes

Certificate of constancy of performance

Annex 1 Page 5 of 5
Certificate holder: SFS Group Italy S.r.l. unipersonale
Date of issue: 21.04.2023



Certificate No.: 0757-CPR-229EG-7051574-13-7

No. 11:

Product designation: **D2DTA 0002**
Hinge type: single-axis three-part door hinge
Material: steel and zamak
Fastening: screw-fitted with 3 screws in frame element
screw-fitted with 4 screws in leaf element
Test report: 20-004336-PR04 of 21.02.2022

Classification:	2	7	3	0	1	4*	0	10
-----------------	---	---	---	---	---	----	---	----

*Corrosion resistance Class 5 positive, according to EN 1670:2007

Intended use: Intended for use on doors in escape routes without requirements for fire resistance and smoke control

No. 12:

Product designation: **D2DTA 0004**
Hinge type: single-axis three-part door hinge
Material: steel and zamak
Fastening: screw-fitted with 3 screws in frame element
screw-fitted with 4 screws in leaf element
Test report: 20-004336-PR04 of 21.02.2022

Classification:	2	7	3	0	1	4*	0	10
-----------------	---	---	---	---	---	----	---	----

*Corrosion resistance Class 5 positive, according to EN 1670:2007

Intended use: Intended for use on doors in escape routes without requirements for fire resistance and smoke control