

Certificate of Constancy of Performance



Certificate No.: 0757-CPR-229EG-9021043-1-2

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Door hinges

Product description/
specification

Single Axis Hinge

According to configuration in **annex 1**

Levels and classes of
performance

According to configuration in **annex 1**

Intended use(s)

Intended for use on doors in escape routes with and without requirements for fire resistance and smoke control

placed on the market
under the name or trade
mark of

La Florida s.r.l.

Via Foscarini 12, IT-31040 Nervesa della Battaglia

and produced in the
manufacturing plant(s)

La Florida s.r.l.

Via Foscarini 12, IT-31040 Nervesa della Battaglia

Notified body No.

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 1935 : 2002

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 11.12.2025 and will remain valid until 10.12.2028, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.


The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 229EG 9021043.

Basis:

EN 1935-2002-02/AC:2003-12



Pascal Geiger
Deputy head of the notified product certification body
Certification & Surveillance Body
ift Rosenheim
15.12.2025



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/ift-zertifiziert
ID: EAB-3FB9F

Certificate of constancy of performance

Annex 1 Page 1 of 2
 Certificate holder: La Florida s.r.l.
 Date of issue: 15.12.2025



Certificate 0757-CPR-229EG-9021043-1-1

Compilation of hinges

Classification key as per EN 1935:2002-05

1	2	3	4	5	6	7	8
Category of use	Durability test cycles	Test door mass	Fire/smoke suitability	Safety	Corrosion resistance	Security	Hinge grade

No.	Product	Hinge type	Material	Reference-test report dated	1	2	3	4	5	6	7	8
1**	165PTM1	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	0	1	*	0	10
2***	165PTM	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	1	1	*	0	10
3***	165P M61	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	1	1	*	0	10
4***	165P M6	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	1	1	*	0	10
5**	165P M8	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	0	1	*	0	10
6***	165P M1	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	1	1	*	0	10
7**	165P M4	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	0	1	*	0	10
8**	165P MP11	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	0	1	*	0	10
9**	165P MP1	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	0	1	*	0	10
10***	165P1M	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	1	1	*	0	10
11***	165PBM	single-axis hinge	steel	22-002533-PR02 of 12.12.2025	2	7	3	1	1	*	0	10

* Class 1/2/3/5 depending on surface coating (see also Table 1 in expert statement 22-002533-PR02)

AG- nickel plated:
 AP- black plasticized zinc:
 AR- grey plasticized zinc:
 AS- white plasticized zinc:
 AM- zinc:
 AO- black zinc:
 BB- matt chrome:
 BMG- zinc nickel:
 BMG- zinc 12micron finingard:
 IUB- Inox 304:

Class 1
 Class 5
 Class 5
 Class 5
 Class 3
 Class 5
 Class 2
 Class 5
 Class 3
 Class 5

** Intended for use on doors in escape routes without requirements for fire resistance and smoke control

*** Intended for use on doors in escape routes with requirements for fire resistance and smoke control

Certificate of constancy of performance

Annex 1 Page 2 of 2
Certificate holder: La Florida s.r.l.
Date of issue: 15.12.2025



Certificate 0757-CPR-229EG-9021043-1-1

No.	Product	Hinge type	Material	Reference-test report dated	1	2	3	4	5	6	7	8
1**	681	single-axis hinge	steel, aluminium, plastic	24-003890-PR04 of 10.12.2025	2	7	3	0	1	4*	0	10
2**	682	single-axis hinge	steel, aluminium, plastic	24-003890-PR04 of 10.12.2025	2	7	3	0	1	4*	0	10
3**	683	single-axis hinge	steel, aluminium, plastic	24-003890-PR03 of 10.12.2025	3	7	4	0	1	4*	0	11
4**	684	single-axis hinge	steel, aluminium, plastic	24-003890-PR03 of 10.12.2025	3	7	4	0	1	4*	0	11
5**	685	single-axis hinge	steel, aluminium, plastic	24-003890-PR03 of 10.12.2025	3	7	4	0	1	4*	0	11
6**	685-1	single-axis hinge	steel, aluminium, plastic	24-003890-PR03 of 10.12.2025	3	7	4	0	1	4*	0	11

*Corrosion resistance class 5 according to EN 1670:2007 fulfilled

** Intended for use on doors in escape routes without requirements for fire resistance and smoke control