

Certificate of Constancy of Performance



Certificate No.: 0757-CPR-230EG-9021623-2-1

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Basis:

EN 12209-2003:+AC:2005-12

Mechanically operated mortise lock

Product description/
specification

111 - 311 - 511

According to configuration in **annex 1**

Levels and classes of
performance

According to configuration in **annex 1**

Intended use(s)

Intended for use on doors with requirements for fire resistance and smoke control

placed on the market
under the name or trade
mark of

STV Serrature srl

Zona Industriale Piana 29, IT-36078 Valdagno VI

and produced in the
manufacturing plant(s)

STV Serrature srl

Zona Industriale Piana 29, IT-36078 Valdagno VI

Notified body No.

0757


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)



EN 12209:2003+AC:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 26.02.2025 and will remain valid until 25.02.2028, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 230EG 9021623.


Dr. Gerhard Wackerbauer, Dipl. Phys.
Deputy Head of Product Certification
Certification & Surveillance Body
ift Rosenheim
26.02.2025



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/
ift-zertifiziert
ID: 8FD-CF49F

Certificate of constancy of performance

Annex 1 Page 1 of 1
Certificate holder: STV Serrature srl
Date of issue: 26.02.2025



Certificate No.: 0757-CPR-230EG-9021623-2-1

Compilation of locks:

	Category of use	Durability	Door mass and closing force	Suitability for use on fire / smoke doors	Safety	Corrosion resistance	Security and drill resistance	Field of door application	Type of key operation and locking	Type of spindle operation	Key identification
Classification	2	S	8	1	0	A	-/-*	B	A	1	0

*As the minimum requirements for counterforce absorption were not met, it is not possible to classify the protection effect. The minimum class to be fulfilled at this point is class 1. For this reason, the test was carried out "based on" the standard version

Intended use: Intended for use on doors with requirements for fire resistance and smoke control

Test report: 24-002779-PR01 of 26.02.2025
24-002779-PR02 of 26.02.2025

No.	Designation	Backset [mm]	Distance [mm]	Overlap design [mm]
1	111 - 311 - 511	20-25-30-35	85	238 x 22