

# Certificate of Constancy of Performance



Certificate n°: 0757-CPR-277-9045513-1-1

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Basis:

EN 16034  
EN 14351-1

## Pedestrian doorsets with fire resistance characteristics

Trade name

**M84 FR Alumil**

Product description/  
specification

Pedestrian doorsets according to EN 14351-1:2006+A2:2016 with fire resistance characteristics according to EN 16034:2014  
Classification: see classification reports n°  
FIRES-CR-194-21-AUPE dated 05.08.2021  
FIRES-CR-195-21-AUPE dated 05.08.2021  
FIRES-CR-196-21-AUPE dated 13.09.2021  
FIRES-CR-197-21-AUPE dated 13.09.2021  
FIRES-CR-291-21-AUPE dated 01.12.2021  
FIRES-CR-130-22-AUPE dated 18.07.2022

Levels and classes of performance

According to configuration in **annex 1**

Intended use(s)

- Installation in residential and non-residential construction
- In the case of room partitioning into fire and/or smoke protection sections and/or escape routes

placed on the market under the name or trade mark of

**KYRIAKOS KARMENOS ALUMINIUM LTD**  
16 STYLIANOU LENA , CY-1028 NICOSIA

and produced in the manufacturing plant(s)

**KYRIAKOS KARMENOS ALUMINIUM LTD**  
16 STYLIANOU LENA , CY-1028 NICOSIA

Notified body No.

**0757**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)



**EN 14351-1:2006+A2:2016** and **EN 16034:2014**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 14.04.2025 and will remain valid until 13.04.2028, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift Rosenheim** no. 277 9045513.

Dr. Gerhard Wackerbauer  
Deputy head of the notified product certification body  
Certification & Surveillance Body  
**ift Rosenheim**  
14.04.2025



[www.ec.europa.eu](http://www.ec.europa.eu)

Identity check



[www.ift-rosenheim.de/](http://www.ift-rosenheim.de/)  
ift-zertifiziert  
ID: 322-13E03

# Certificate of constancy of performance

Annex 1 Page 1 of 1  
Certificate holder: KYRIAKOS KARMENOS ALUMINIUM LTD  
Date of issue: 14.04.2025



Certificate n°: 0757-CPR-277-9045513-1-1

## Product description:

Essential characteristics according to EN 16034	Performance
<b>Fire resistance</b> (in the case of room partitioning into fire and/or smoke protection sections)	NPD / E 15 / E 20 / E 30 / E 45 / E 60 NPD / EW 15 / EW 20 / EW 30 / EW 45 / EW 60 NPD / EI <sub>2</sub> 15 / EI <sub>2</sub> 20 / EI <sub>2</sub> 30 / EI <sub>2</sub> 45 / EI <sub>2</sub> 60* NPD / EI <sub>1</sub> 15 / EI <sub>1</sub> 20 / EI <sub>1</sub> 30 / EI <sub>1</sub> 45 / EI <sub>1</sub> 60*  * differing classification for glass Polflam: NPD / EI <sub>2</sub> 15 / EI <sub>2</sub> 20 / EI <sub>2</sub> 30 / EI <sub>2</sub> 45 NPD / EI <sub>1</sub> 15 / EI <sub>1</sub> 20 / EI <sub>1</sub> 30 / EI <sub>1</sub> 45
<b>Smoke control</b> (only for applications where smoke spread limitation is required)	NPD
<b>Ability to release</b>	NPD / Released
<b>Self-closing action</b> (only for self-closing fire and/or smoke protection doors and/or windows)	NPD / C
<b>Durability of ability to release</b>	NPD / Maintain release
<b>Durability of self-closing</b> (only for self-closing fire and/or smoke protection doors and/or windows) – Compared with loss of quality (resistance to repeated opening and closing) – Compared with ageing (corrosion)	NPD  NPD / Achieved