

Certificate of Constancy of Performance



Certificate No.: 0757-CPR-229IFT-7031575-2-4

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Basis:

EN 1935-2002-02/AC:2003-12

Door hinges

Product description/
specification

ROTO SOLID C

According to configuration in **annex 1**

Levels and classes of
performance

According to configuration in **annex 1**

Intended use(s)

Intended for use on doors in escape routes without requirements for fire resistance and smoke control

placed on the market
under the name or trade
mark of

ROTO FRANK AUSTRIA GmbH

Lapp-Finze-Str. 21, AT-8401 Kalsdorf bei Graz

and produced in the
manufacturing plant(s)

ROTO FRANK AUSTRIA GmbH

Lapp-Finze-Str. 21, AT-8401 Kalsdorf bei Graz

Notified body No.

0757



This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)


EN 1935 : 2002

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 08.02.2017 and will remain valid until 07.02.2029, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 229IFT 7031575.

Dr. Gerhard Wackerbauer
Deputy head of the notified product certification body
Certification & Surveillance Body
ift Rosenheim
08.02.2026



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/
ift-zertifiziert
ID: 29E-2FEC1

Certificate of constancy of performance

Annex 1 Page 1 of 1
Certificate holder: ROTO FRANK AUSTRIA GmbH
Date of issue: 08.02.2026



Certificate No.: 0757-CPR-229IFT-7031575-2-4

Compilation of hinges

Classification key as per EN 1935:2002-05

1	2	3	4	5	6	7	8
Category of use	Durability test cycles	Test door mass	Fire/smoke suitability	Safety	Corrosion resistance	Security	Hinge grade

No.	Product	Hinge type	Material	Reference-test report dated	1	2	3	4	5	6	7	8
					2	7	3	0	1	4*	0	10
1**	ROTO SOLID C / C7.140	1-axis, 3-part, concealed belt	Zinc alloy	16-003602-PR01 07.02.2017	2	7	3	0	1	4*	0	10

* Additional testing has proven that the requirements of class 5 according to DIN EN 1670:2007 are fulfilled.

** Intended for use on doors in escape routes without requirements for fire resistance and smoke control