

Certificate of Constancy of Performance



Certificate No: 0757-CPR-286-8005373-1-5

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Grundlage(n):

EN 12101-10:2005+AC:2007-02



Power supplies in smoke and heat control systems

Smoke and heat control systems - Power supplies

Product description/
specification

Control units and power Supply: see annex 1
Battery: see annex 1
See documentary evidence no. 20-001548-PR01

Levels and classes of
performance

Operational class A, environmental class 1

Intended use(s)

Power supply units for the application in smoke and heat control systems

placed on the market
under the name or trade
mark of

ULTRAFLEX CONTROL SYSTEMS s.r.l.

Via XXV Aprile 45, IT-16012 Busalla GE

and produced in the
manufacturing plant(s)

ULTRAFLEX CONTROL SYSTEMS s.r.l.

Via XXV Aprile 45, IT-16012 Busalla GE

Notified body No.
EC-Reference-No.

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12101-10:2005 + AC:2007



under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 29.06.2020 and will remain valid until 28.06.2026, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 286 8005373.

Christian Kehrer

Christian Kehrer
Head of notified product certification body
ift Rosenheim
26.07.2023



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/
ift-zertifiziert
ID: ACB-28021

Certificate of Constancy of Performance

Annex 1 Page 1 of 1
Manufacturer: ULTRAFLEX CONTROL SYSTEMS s.r.l.
Date: 26.07.2023



Certificate no: 0757-CPR-286-8005373-1-5

Product description/ specification

Control Units	24 V - 20 A: C-SV 20A C-SV IB 20A	24 V - 8 A: C-SV 8A C-SV IB 8A	24 V - 4 A: C-SV 4A C-SV IB 4A
Power Supply	<u>Chinfa Electronics</u> DRA 480 - 24 - A (screw terminal type)	<u>Meanwell</u> HRP-200-24	<u>Meanwell</u> LRS-100-24
Battery	<u>Elcart</u> ELB +9-12 - 12V / 9,0 Ah	<u>Elan</u> BigBat 12V . 4.5 Ah. - 12V / 4,5 Ah	
	<u>Yuasa</u> NP7-12 - 12V / 7,0 Ah	<u>Yuasa</u> NP4-12 - 12V / 4,0 Ah	