# **Certificate of Constancy** of Performance

### Certificate No.: 0757-CPR-288-9004008-1-6

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

## Smoke and heat control system (NSHEV)

#### Enev-kit JK

Profile system: sendzimierverzinktes Blech see ift Product Passport no. 12-001343-PR12

Levels and classes of performance

Product description/

specification

Intended use(s)

placed on the market under the name or trade mark of

and produced in the manufacturing plant(s)

Notified body No. EC-Reference-No.

Requirements fulfilled

This NSHEV was tested without side wind influence. Therefore, use of this NSHEV is allowed only in mounting positions without risk caused by exposure to side wind flow i.e. use in side walls. For notes on use refer to product passport No. 12-001343-PR12. Design and dimensions of the NSHEV are subject to the relevant national rules and regulations concerning use and application.

#### Aleatec GmbH

Buschkoppel 1, DE-21493 Schwarzenbek

#### Aleatec GmbH

0757

Buschkoppel 1, DE-21493 Schwarzenbek

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 12101-2 : 2003


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 23.11.2015 and will remain valid until 18.02.2027, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the ift Rosenheim no. 288 9004008.

Christian Kehrer Head of notified product certification body ift Rosenheim 08.04.2024





www.ec.europa.eu

**Identity check** 



www.ift-rosenheim.de/ ift-zertifiziert ID: 1DE-C3C65

ift Rosenheim GmbH

Theodor-Gietl-Str. 7-9 D-83026 Rosenheim

Contact Phone: +49 8031 261-0 Fax: +49 8031 261-290 www.ift-rosenheim.de

Testing and Calibration – EN ISO/IEC 17025 Inspection – EN ISO/IEC 17020 Product Certification – EN ISO/IEC 17065 Certification of Management Systems – EN ISO/IEC 17021







Basis: EN 12101-2:2003-06

