Certificate of Constancy of Performance

Certificate n^e: 0757-CPR-277-6080181-6-2

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

External door as per EN 14351-1:2006+ A2:2016 with fire resistance and/or smoke control as per EN 16034:2014

Product range "H120 OD" with trade name "H120-1 OD" and "H120-2 OD"

Steel, hinged, single and double leaf doors corresponding to EN 14351-1. Construction and classification: see EXAP-reports no. 01653.2/20/R131NZP and 01653/20/R131NZP as well as classification reports no. 01653.1/20/R131NZP and 01653.3/20/R131NZP

According to configuration in annex 1

- Installation in residential and non-residential construction

- In the case of room partitioning into fire and/or smoke protection sections and/or escape routes

placed on the market Hörmann KG Verkaufsgesellschaft under the name or trade Upheider Weg 94-98, DE-33803 Steinhagen

Hörmann KG Verkaufsgesellschaft and produced in the manufacturing plant(s)

Upheider Weg 94-98, DE-33803 Steinhagen

Notified body No. FC-Reference-No.

Trade name

specification

performance

Intended use(s)

mark of

Product description/

Levels and classes of

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 14351-1:2006+A2:2016 and EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 09.06.2021 and will remain valid until 08.06.2024, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the ift Rosenheim no. 277 6080181.





Christian Kehrer Head of notified product certification body




ROSENHEIM











www.ift-rosenheim.de

ift Rosenheim GmbH

/e-Zer-6274-de / 01.01.2021

Theodor-Gietl-Str. 7-9 D-83026 Rosenheim

Contact Phone: +49 8031 261-0 Fax: +49 8031 261-290 www.ift-rosenheim.de

Testing and Calibration – EN ISO/IEC 17025 Inspection – EN ISO/IEC 17020 Product Certification – EN ISO/IEC 17065 Certification of Management Systems – EN ISO/IEC 17021

Notified Body 0757 PÜZ-Stelle: BAY 18



Certificate of constancy of performance

Date of issue:

Annex 1 Page 1 of 1 Certificate holder: Hörmann KG Verkaufsgesellschaft 17.06.2021

Certificate n°: 0757-CPR-277-6080181-6-2



Product description:

Essential characteristics	Performance	Harmonised technical specification
Fire resistance (Room arrangement in fire and/or smoke control sections)	NPD / E 15 / E 20 / E 30 / E 45 / E 60 / E 90 / E 120 NPD / EW 15 / EW 20 / EW 30 / EW 45 / EW 60 / EW 90 / EW 120 NPD / El ₂ 15 / El ₂ 20 / El ₂ 30 / El ₂ 45 / El ₂ 60 / El ₂ 90 / El ₂ 120 NPD / El ₁ 15 / El ₁ 20 / El ₁ 30	
Smoke protection (only for applications, where limiting the spread of smoke is required)	NPD / Sa / S200	
Ability to release	NPD / released	EN 16034:2014
Self-closing (only for self-closing fire and/or smoke control door and/or windows)	NPD / C	
Durability of ability to release	NPD	
Durability of self-closing (only for self-closing fire and/or smoke control door and/or windows) – regarding loss of quality (Durability) – regarding aging (Corrosion)	NPD / 0 / 1 / 2 / 3 / 4 / 5 NPD	
Ability to release	Requirement fulfilled	EN 14351-1: 2006+A2:2016